

# ADDENDUM NUMBER TWO

## SANTEE SCHOOL DISTRICT

**Bid #1920-001-077**

**Old Lockers/Shower Interior Demolition at Chet F. Harritt School Site**

DATE: June 11, 2019

General - All project documents including contract documents, drawings, and specifications, shall remain unchanged with the exception of those elements added, revised, deleted, or clarified by this addendum. **Acknowledge receipt of Addendum Number TWO in the appropriate place provided on the Bid Form**

ITEM NO. 1 ADDENDUM TWO	Clarifications and corrections to demolition notes and key notes
----------------------------	--

- A) All P.E. lockers will be removed and salvaged and stored BY OTHERS.
- B) Demolish existing ceiling plaster and glue up acoustic ceiling tiles below roof framing.
- C) DISTRICT STAFF will salvage and store and disconnect water heater, dish washer, and kilns and remove and store before construction starts.
- D) Existing low-voltage network system conduits above dropped T-bar ceiling through on a suspended rack system TO REMAIN PROTECTED IN PLACE and left intact.
- E) Remove and SALVAGE, DO NOT Demo:
  - 1. Toilet, shower, restroom accessories and fixtures,
  - 2. Uncut, undamaged 2 by 4 whole dropped ceiling tiles.
  - 3. Toilet partitions, benches, grab bars, restroom dispensers for soap and paper and toilet tissue.
  - 4. Door hardware and locks, flush valves and plumbing fixtures, drinking fountains, sinks and mirrors, shelves and fixtures and RETURN TO DISTRICT.
- F) Where "Drywall" or "GYP" is mentioned to be removed, assume it is "Plaster".
- G) Walls remaining - remove all plaster and terrazzo to wood stud.
- H) During ceiling demolition, Safe-off existing lights to roof structure. LIGHTS TO REMAIN PROTECTED and in working condition. Provide temporary switch in each space affixed to existing wall wood stud framing as directed by project manager.

## END OF ADDENDUM TWO

**SANTEE SCHOOL DISTRICT**

**Bid #1920-001-077**

**Old Lockers/Shower Interior Demolition at Chet F. Harritt School Site**

<p>ADDENDUM NUMBER TWO</p> <p><b>SANTEE SCHOOL DISTRICT</b></p> <p><b>Bid #1920-001-077</b></p> <p><b>Old Lockers/Shower Interior Demolition at Chet F. Harritt School Site</b></p>
---